



REYNOSA
TAMAULIPAS
ESTADO DE TAMAULIPAS

COMAPA
REYNOSA
Comisión Municipal de Agua Potable y
Alcantarillado del Municipio de Reynosa



TODOS POR
TAMAULIPAS

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
OCTUBRE 2015

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	NOM-127/94	PROMEDIO	
TURBIEDAD N.T.U.	15.2	16.2	15.1	15.1	15.9	14.0	15.2	19.2	13.7	15.9	17.8	14.2	12.1	13.2	13.7	11.3	13.3	25.3	17.4	14.3	14.2	14.2	14.2	5 NTU.	15.3
P.H.	7.7	7.6	7.6	7.7	7.6	7.7	7.8	7.7	7.8	7.7	7.7	7.8	7.7	7.7	7.8	7.6	7.6	7.7	7.8	7.7	7.7	7.8	7.7	6.5-8.5	7.7
ALCALINIDAD TOTAL	120	120	86	114	110	128	120	88	128	106	116	126	120	116	102	98	120	96	116	98	126	118		112.4	
DUREZA TOTAL	330	370	326	314	326	326	320	310	318	300	322	286	300	290	290	324	330	244	250	316	324	320	500 MG/LT	310.7	
CLORUROS	204	180	196	209	195	193	200	150	192	182	180	175	171	168	145	188	190	182	168	200	190	218	250 MG/LT	185.3	
CALCIO	194	200	184	190	174	214	180	182	200	180	198	190	162	160	168	194	180	136	140	182	180	190		180.8	
MAGNESIO	136	170	142	124	152	112	140	128	118	120	124	96	138	130	122	130	150	108	110	134	144	130		129.9	
SDT	682	610	664	647.5	630	637.5	630	564	601	597	542	565	575	574	585	590	607	512	535	537.5	589	612.5	1000 MG/LT	594.9	

QFB. MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.

Xc. Bo.
BIÓLOGO GUILLERMO LUANO
COORDINADOR DE CALIDAD DEL AGUA