

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
NOVIEMBRE 2015

RESULTADOS EN MG/LT																															
FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	NOM127/94	PROMEDIO									
TURBIEDAD N.T.U.	2.8	2.5	2.5	1.8	2.3	4.3	3.9	4.3	4.5	4.4	3.0	4.7	4.5	3.2	3.6	4.3	4.8	3.4	4.4	4.2	5 NTU.	3.7									
P.H.	7.4	7.5	7.4	7.4	7.5	7.4	7.5	7.5	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.5	7.5	7.4	7.3	6.5-8.5	7.4									
ALCALINIDAD TOTAL	112	108	112	108	118	116	118	120	110	122	130	138	138	140	136	140	122	128	146	126		124.4									
DUREZA TOTAL	310	336	314	348	350	322	328	306	308	294	354	376	368	388	380	394	362	380	396	350	500 MG/LT	348.2									
CLORUROS	215	235	244	250	240	250	250	229	220	215	250	285	342	316	290	298	267.5	300	240	230	250 MG/LT	258.3									
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.2	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	0.2-1.5 MG/LT	1.5									
CALCIO	220	214	214	222	200	200	218	188	230	208	236	200	244	252	288	266	286	248	270	212		229.8									
MAGNESIO	90	122	100	126	150	122	110	118	78	86	118	176	124	136	142	128	76	132	126	138		119.9									
SDT	675	706	745	747	761.5	620	690	635	654.5	660	790	810	801	787	790	770	749.5	752	768	720	1000 MG/LT	731.6									


QFB MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.

Vo.Bo. 
OLEGO GUILLERMO NAVA LUJAN
ORDINADOR DE CALIDAD DEL AG