



● REYNOSA
● TAMAUlipas
● GOBIERNO DEL ESTADO

● COMAPA
● REYNOSA
Comisión Municipal de Agua Potable y
Asesoría del Municipio de Reynosa



TODOS POR
TAMAUlipas

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS

AGUA CRUDA
AGOSTO 2016

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	21.0	16.0	18.1	16.6	17.3	20.3	21.4	32.3	23.5	15.4	18.9	15.2	18.9	13.6	12.1	13.0	12.8	18.0	13.2	17.8	14.7	20.3	17	5 NTU.	17.7
P.H.	7.8	7.6	7.8	7.8	7.7	7.8	7.8	7.7	7.7	7.6	7.7	7.7	7.7	7.7	7.7	7.7	7.6	7.7	7.7	7.7	7.6	7.7	7.6	6.5-8.5	7.7
ALCALINIDAD TOTAL	84	90	70	80	82	68	72	70	74	70	64	66	64	52	56	60	58	60	56	560	52	54	58		87.8
DUREZA TOTAL	240	320	290	250	258	260	280	290	250	280	270	276	278	320	318	260	264	266	270	294	290	270	296	500 MG/LT	277.0
CLORUROS	240	230	230	220	220	231	220	230	235	240	180	195	200	210	210	220	235	230	230	250	250	230	240	250 MG/LT	225.0
CALCIO	160	174	170	150	160	162	164	170	164	158	160	162	160	148	160	130	138	172	170	224	220	160	180		165.0
MAGNESIO	80	146	120	100	98	98	116	120	86	102	110	114	118	172	158	130	126	94	100	70	70	110	136		111.9
SDT	552	555	555	521.5	535	540	565	560	540	540	560	570	550	570	540	562.5	585	615	615	596	556	565	570	1000 MG/LT	561.7

QEB. MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO.

Vo.Bo.
BILOSANT GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA