

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
SEPTIEMBRE 2016

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	19	20	21	22	23	26	27	28	29	30	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	5.0	4.1	4.9	5.0	4.4	5.0	4.8	4.4	2.5	2.8	5.0	4.4	2.9	3.9	4.0	3.4	2.7	3.4	3.4	5.2	5 NTU.	4.1
P.H.	7.3	7.4	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.2	7.3	7.3	7.3	7.4	7.3	7.2	7.2	7.3	7.2	6.5-8.5	7.3
ALCALINIDAD TOTAL	54	56	56	52	46	46	48	82	74	72	70	64	58	60	58	48	74	72	68	68	50		60.8
DUREZA TOTAL	296	316	270	276	256	258	268	312	280	284	290	196	210	212	220	190	194	196	182	196	196	500 MG/LT	242.9
CLORUROS	248	252	230	236	234	238	240	153	150	156	165	130	136	146	164	110	108	110	126	128	170	250 MG/LT	172.9
CLORO RESIDUAL	1.2	1.0	1.0	1.1	0.9	1.1	1.0	1.2	1.2	1.1	1.5	1.2	1.2	1.1	1.2	1.0	1.2	1.1	1.5	1.5	2.0	0.2-1.5 MG/LT	1.2
CALCIO	176	186	176	176	184	186	190	160	186	184	190	140	156	162	164	150	150	160	148	150	170		168.8
MAGNESIO	120	130	94	100	72	72	78	152	94	100	100	56	54	50	56	40	44	36	34	48	26		74.1
SDT	600	595	600	600	590	595	597.5	580	560	600	615	622.5	565	580	570	550	522.5	560	560	565	560	1000 MG/LT	580.4



OFB MIRIAM OAVAZOS GARCIA
JEFE DE LABORATORIO.



BIROGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA