

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
NOVIEMBRE 2015

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	17.0	15.2	14.5	13.8	9.9	18.9	11.9	9.8	14.3	14.2	16.3	13.8	12.8	15.7	18.2	17.8	15.3	14.3	11.6	14.3	5 NTU	14.5
P.H.	7.6	7.5	7.7	7.8	7.6	7.9	7.8	7.8	7.5	7.5	7.3	7.7	7.6	7.5	7.5	7.6	7.7	7.6	7.6	7.3	6.5-8.5	7.6
ALCALINIDAD TOTAL	116	120	119	124	130	120	110	130	126	134	118	138	140	140	130	150	124	136	140	132		128.9
DUREZA TOTAL	304	310	354	350	380	360	336	326	316	312	366	380	396	380	398	416	364	392	390	338	500 MG/LT	358.4
CLORUROS	209	230	240	246	260	250	222	219	215	216	250	288	375	263	390	294	285	271	250	243	250 MG/LT	259.8
CALCIO	210	198	216	224	230	180	206	168	238	202	164	210	230	246	260	250	282	212	240	214		219.0
MAGNESIO	94	112	138	156	150	180	130	158	78	110	202	170	166	134	138	166	821	180	150	124		177.9
SDT	675	720	741	728	762	730	630	655	635	665	808	784	808	797	775	760	755	753	753	684	1000 MG/LT	730.9


QFB-MIRIAM-CAVAZOS GARZA
ENCARGADA DE LABORATORIO.


RICARDO CALDERERO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA.