

PLANTA POTABILIZADORA PASTOR LOZANO  
ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA  
DICIEMBRE 2015

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	28	29	30	31	NOM-127/94	PROMEDIO	
TURBIEDAD N.T.U.	13.4	13.7	14.1	17.4	12.1	12.2	12.2	10.2	12.8	13.7	14.6	17.1	18.4	17.0	13.9	17.7	15.0	15.0	14.8	13.1	14.0	13.1		16.3	14.3
P.H.	7.5	7.6	7.8	7.5	7.7	7.6	7.6	7.6	7.5	7.6	7.5	7.6	7.2	7.6	7.7	7.7	7.7	7.7	1.5	7.8	7.5	7.6		6.5-8.5	7.3
ALCALINIDAD TOTAL	130	144	130	140	120	122	130	126	144	108	140	104	124	120	130	114	120	120	120	120	122	110	120		124.5
DUREZA TOTAL	370	360	396	358	354	326	334	334	320	380	370	386	364	368	346	376	380	370	360	368	680	354		500 MG/LT	375.2
CLORUROS	218	190	170	199	171	198	220	219	180	190	195	196	222	200	160	190	192	198	177	177	178	195		250 MG/LT	192.5
CALCIO	226	208	192	172	240	208	206	210	190	200	230	206	250	240	206	210	210	200	180	200	208	204		208.9	
MAGNESIO	144	152	204	186	114	118	128	124	130	180	140	180	128	128	146	166	170	170	180	168	172	150		153.5	
SDT	683	665	635	780	631	637	634	619	600	626	643	360	628	615	645	595	585	575	605	605	612	627	1000 MG/LT	618.4	

  
QFB. MIRIAM CAVAZOS GARZA  
ENCARGADA DE LABORATORIO.

  
BIODORO GUILLERMO NAVAJUANO  
COORDINADOR DE CALIDAD DEL AGUA

Ve-86.