

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA POTABLE  
OCTUBRE 2016

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	30	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.3	5.4	5.4	4.6	4.9	5.7	5.0	5.0	7.2	6.6	5.7	7.1	8.6	5.0	4.0	3.9	5.0	5.0	4.7	4.0	4.3	5 NTU.	5.3
P.H.	7.2	7.3	7.3	7.4	7.4	7.3	7.3	7.3	7.2	7.2	7.2	7.3	7.2	7.2	7.3	7.3	7.1	7.4	7.3	7.5	7.45	6.5-8.5	7.3
ALCALINIDAD TOTAL	90	58	56	52	70	60	62	68	56	70	102	98	102	110	106	88	108	100	64	66	64		78.6
DUREZA TOTAL	198	248	180	240	238	270	278	280	284	284	292	240	270	270	258	254	262	266	274	312	280	500 MG/LT	260.9
CLORUROS	95	107	103	85	100	115	117	120	115	139	210	118	124	129	190	164	178	167	160	174	140	250 MG/LT	135.7
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.5	0.6	0.8	1.0	1.5	1.5	1.5	1.4	1.0	1.5	0.2-1.5 MG/LT	1.4
CALCIO	158	180	124	168	160	166	186	178	170	198	210	178	192	192	190	152	162	178	202	174	160		175.1
MAGNESIO	40	68	56	72	78	104	92	102	114	86	82	62	78	78	68	102	100	88	72	138	120		85.7
SDT	544	535	535	497	457	564	553	549	543	536	517	528	547	557	557	536	515	520	534	517	560	1000 MG/LT	533.2

  
OFELIA MIRIAM PAVEZOS GARCIA  
JEFE DE LABORATORIO.

  
Vo.Bo.  
BIÓLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA