

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
OCTUBRE 2016

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	14.3	12.3	12.3	11.5	11.5	10.9	11.9	10.1	13.8	13.6	16.9	15.3	15.3	14.7	13.4	10.8	12.3	12.4	13.1	12.7	11.5	5 NTU.	12.9
P.H.	7.7	7.7	8.1	7.8	7.9	7.8	7.7	7.7	7.9	8.3	7.7	7.7	7.7	7.7	7.7	7.5	7.8	7.7	7.8	7.9	7.7	6.5-8.5	7.8
ALCALINIDAD TOTAL	62	64	56	56	74	70	54	62	64	92	130	108	130	86	98	82	84	98	78	68	66		80.1
DUREZA TOTAL	196	240	180	230	232	260	300	296	322	298	284	270	292	296	294	296	284	264	270	302	290	500 MG/LT	271.2
CLORUROS	100	98	93	80	98	110	110	110	110	111	122	110	114	116	121	116	162	159	152	147	135	250 MG/LT	117.8
CALCIO	150	174	160	168	140	180	192	170	176	220	192	170	172	204	120	150	110	170	162	202	154		168.4
MAGNESIO	46	66	20	62	92	80	108	126	146	78	92	100	120	92	174	146	174	94	108	100	136		102.9
SDT	525	520	520	455.5	435	561.5	570	533.5	516.5	530	510	519	522.5	540	537.5	517	514.5	506.5	565	519.5	495	1000 MG/LT	519.7


QFB MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO.


Vo.Bo.
BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA