

PLANTA POTABILIZADORA PASTOR LOZANO  
ANÁLISIS FÍSICOQUÍMICOS  
AGUA POTABLE  
NOVIEMBRE 2016

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	22	23	24	25	28	29	30	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.9	4.6	4.4	3.8	4.0	4.0	3.4	3.3	3.5	2.9	2.6	4.7	4.6	3.5	3.4	4.2	2.9	2.6	2.5	3.2	2.6	5 NTU.	3.6
P.H.	7.5	7.6	7.5	7.4	7.5	7.5	7.4	7.3	7.3	7.4	7.4	7.4	7.3	7.4	7.5	7.4	7.4	7.2	7.1	7.4	7.4	6.5-8.5	7.4
ALCALINIDAD TOTAL	62	66	60	74	64	66	64	66	76	68	78	68	68	68	76	72	76	78	68	70	76		66.7
DUREZA TOTAL	274	240	250	256	240	280	286	248	240	238	238	240	264	260	270	220	250	274	290	280	264	500 MG/LT	257.2
CLORURO	160	180	162	177	167	163	166	166	146	165	163	160	160	168	185	185	180	195	175	160	158	250 MG/LT	168.6
CLORO RESIDUAL	1.3	1.2	1.5	1.5	1.4	1.5	1.2	1.3	1.5	1.2	1.0	1.2	1.0	0.8	0.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5 MG/LT	1.3
CALCIO	160	146	160	170	158	192	194	196	164	170	160	160	158	160	170	170	180	190	170	170	166		169.7
MAGNESIO	114	94	90	86	82	88	92	52	76	68	78	80	106	100	100	50	70	84	120	110	98		87.5
SDT	515	514	520	510	515	490	493	498	499	530	508	475	496	510	589	560	558	555	550	550	550	1000 MG/LT	523.0

  
OFE. MIRIAM CAVAZOS GARCIA  
JEFE DE LABORATORIO.

  
Va. Bo.  
BIÓLOGO GUILHERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA