

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
DICIEMBRE 2016

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	10.9	10.7	11.0	10.8	11.0	10.9	10.0	10.1	14.3	13.6	10.9	10.8	10.9	10.6	13.9	12.0	10.6	11.7	10.4	10.8	9.6	16.0	5 NTU.	11.4
P.H.	8	7.8	8.1	7.9	8.1	8.1	8	8	7.9	7.8	7.9	7.9	7.9	7.9	7.8	7.9	8	8.1	8	8.3	8.3	7.8	6.5-8.5	8.0
ALCALINIDAD TOTAL	78	76	72	88	92	80	82	84	76	80	80	82	90	94	90	90	86	82	84	96	94	96		85.1
DUREZA TOTAL	256	258	244	250	290	280	290	244	260	268	280	286	310	320	306	280	300	294	320	322	330	334	500 MG/LT	287.4
CLORUROS	180	168	180	185	205	203	210	150	155	165	157	150	170	175	176	180	185	184	175	181	173	190	250 MG/LT	177.1
CALCIO	180	180	140	174	190	190	190	154	160	172	160	162	180	164	180	180	190	202	204	214	208	230		182.0
MAGNESIO	76	78	104	76	100	90	100	90	100	96	120	124	130	156	126	100	110	92	116	108	122	104		105.4
SDT	520	530	570	560	600	595	565	530	520	545	520	600	590	585	550	525	538	539	543	544	554	579	1000 MG/LT	554.6

Realizó

OFB MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO

No. 60.

BIOQUÍMICO
COORDINADOR DE CALIDAD DEL AGUA