

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS

AGUA CRUDA

sep-17


RESULTADOS EN MG/LT

TEC. EN	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/04	PROMEDIO
TURBIDIDAD NTU	8.4	8.2	8.8	15.8	13.8	13.1	13.9	10.1	10.9	11.2	10.7	12.0	9.7	11.5	12.0	10.4	11.3	12.0	16.2	18.5	14.2	5 NTU	12.1
pH	7.9	7.8	8.0	8.0	7.9	7.6	7.9	7.7	8.0	8.0	8.0	8.0	8.0	8.2	7.9	7.9	7.8	8.0	8.0	7.8	7.9	6.5-8.5	7.9
RESALDANTE (MG/L)	138	124	134	100	140	132	112	146	112	132	120	126	108	98	112	122	114	124	120	126	130		122.5
DUROZA (MG/L)	332	264	280	278	268	266	270	272	278	298	268	264	240	278	286	286	278	266	260	280	282	500 MG/LT	277.2
CALDRESIS	243	27	204	170	197	194	185	184	185	194	214	202	208	228	230	226	198	218	170	180	226	250 MG/LT	195.2
CLORO	230	284	184	174	180	202	206	200	180	226	190	200	170	170	210	180	196	178	170	180	176		192.7
AMONÍACO	102	114	116	104	88	64	64	72	98	82	88	64	70	108	88	108	80	110	80	80	114		90.0
TOT	547	807	618	518	527	505	514	520	519	524	527	487	535	525	535	530	515	510	517	530	536	1000 MG/LT	525.9

Realizó


MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO

Vo. Bo.


JUAN GUILLERMO NAVA LUIANO
COORDINADOR DE CALIDAD DEL AGUA

