


PLANTA POTABILIZADORA PASTOR LOZANO
ANALISIS FISICOQUÍMICOS
AGUA CRUDA
oct-17

RESULTADOS EN MG/LT


FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	14.5	11.3	10.7	12.2	9.7	8.0	13.0	15.7	9.3	12.5	11.9	10.8	7.9	12.0	10.0	9.1	11.0	11.2	14.8	11.0	12.7	10.5	5 NTU.	11.4
P.H.	8.0	7.5	8.0	7.9	7.2	7.6	7.7	7.8	7.7	7.8	8.0	7.6	7.8	7.9	7.8	7.9	7.7	7.9	7.9	7.7	7.9	7.9	6.5-8.5	7.8
ALCALINIDAD TOTAL	116	122	102	126	122	124	130	132	134	124	114	126	120	142	140	136	132	128	122	132	94	120		124.5
DUREZA TOTAL	250	284	282	272	290	304	300	286	308	320	280	308	300	300	282	276	248	282	288	292	270	262	500 MG/LT	285.6
CLORUROS	170	204	209	206	206	218	213	231	236	230	200	213	204	209	202	191	201	206	204	213	207	181	250 MG/LT	207.0
CALCIO	170	196	212	210	190	190	220	192	184	214	170	192	198	200	198	180	194	180	212	196	160	160		191.7
MAGNESIO	80	88	70	62	100	114	80	94	124	106	110	116	102	100	84	96	54	102	76	96	110	102		93.9
SDT	525	522	515	532	534	530	547	580	598	590	560	560	565	552	533	509	511	535	557	554	528	480	1000 MG/LT	541.7

Realizó



QFB. MIRIAM CÁVAZOS GARCIA
JEFE DE LABORATORIO

Verificó



BIC. JUAN GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA