


**PLANTA POTABILIZADORA PASTOR LOZANO**  
**ANALISIS FISICOQUÍMICOS**  
**AGUA CRUDA**  
 nov-17

RESULTADOS EN MG/LT


FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	21	22	23	24	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	12.4	11.1	12.0	9.1	11.3	11.2	11.4	12.3	12.3	10.4	10.2	8.0	9.2	10.0	9.4	11.2	10.0	10.6	13.2	10.1	9.4	5 NTU.	10.7
P.H.	7.9	7.9	8.3	7.8	8.0	8.0	8.0	8.0	7.9	7.9	8.0	8.0	7.8	7.8	7.8	7.9	7.7	7.4	8.0	7.7	7.4	6,5-8,5	7.9
ALCALINIDAD TOTAL	120	128	126	116	132	134	142	122	136	122	136	126	142	116	122	142	134	120	144	142	144		130.8
DUREZA TOTAL	240	250	246	230	238	232	240	242	228	242	234	234	248	204	224	262	250	190	234	244	244	500 MG/LT	236.0
CLORUROS	190	183	176	165	147	151	158	157	140	146	140	136	122	107	155	148	154	120	165	154	159	250 MG/LT	151.1
CALCIO	156	180	182	150	178	162	178	104	168	178	188	170	170	140	196	200	170	124	184	180	182		168.6
MAGNESIO	84	70	64	80	60	70	62	138	60	64	46	64	78	64	28	62	80	66	50	64	52		67.0
SDT	470	465	450	427	420	405	425	435	393.5	384	388	378	375	403.5	400	403	427.5	441.5	422	410	420	1000 MG/LT	416.3

Realizó



QFB. MIRIAM CAVAZOS GARCIA  
 JEFE DE LABORATORIO

Vb. Bo.



BIDL. JOAN GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA