

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
nov-18

RESULTADOS EN MG/LT

FECHA:	1	5	6	7	8	9	12	13	14	15	16	20	21	22	23	26	27	28	29	30	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	9.9	9.6	10.0	14.0	10.6	8.6	14.8	16.8	15.8	14.0	11.7	10.8	9.1	8.9	2.2	12.2	13.1	7.3	10.0	10.9	5 NTU.	11.0
P.H.	8.1	7.9	7.7	7.8	7.9	7.9	7.6	7.7	7.7	7.8	7.8	7.8	7.9	7.9	7.8	7.6	8.3	7.8	7.9	7.7	6.5-8.5	7.8
ALCALINIDAD TOTAL	130	124	130	126	130	124	98	126	118	102	122	130	122	126	130	130	130	130	134	128		124.5
DUREZA TOTAL	338	292	330	334	304	308	304	316	282	300	300	290	304	308	288	300	312	334	330	326	500 MG/LT	310.0
CLORUROS	250	238	240	250	229	216	211	193	170	182	185	190	195	196	194	202	217	215	237	230	250 MG/LT	212.0
CALCIO	202	180	200	188	206	190	186	192	180	200	186	178	196	206	188	200	206	224	220	216		197.2
MAGNESIO	136	112	130	146	98	118	118	124	102	100	114	112	108	102	100	100	106	110	110	110		112.8
SDT	654	635	643	642	600	560	670	791	690	695	695	520	863	745	694.5	726	781.5	811.5	859	821.5	1000 MG/LT	704.9

Realizó


OFB-MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO

Ver.Bo.


BIOL. JUAN GILBERTO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

COMISIÓN NACIONAL DEL AGUA
CONAGUA

8 ENE 2019

Recepción

ORGANISMO DE GESTIÓN DEL SERVICIO
PROCESO DEL SERVICIO AL CLIENTE
CD. REYNOSA, YUCATAQUÍPES