

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
DICIEMBRE 2018

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	26	27	28	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	4.5	4.1	3.8	5.0	4.0	5.0	5.0	5.0	4.8	2.0	2.1	1.2	2.4	2.5	3.1	3.6	5.0	4.1	5 NTU.	3.7
P.H.	7.6	7.4	7.5	7.6	7.4	7.2	7.3	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.6	7.6	7.5	7.2	6.5-8.5	7.5
ALCALINIDAD TO	128	120	122	130	122	112	118	126	116	120	116	118	122	120	122	108	124	126		120.6
DUREZA TOTAL	328	330	326	328	324	336	322	328	334	314	314	308	316	306	300	316	330	338	500 MG/LT	322.1
CLORUROS	236	241	244	247	237	210	218	211	215	204	226	211	209	250	202	208	227	221	250 MG/LT	223.2
CLORO RESIDUA	1.2	1.4	1.4	1.3	1.1	1.5	1.3	1.1	1.0	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.4
CALCIO	186	200	222	196	170	208	190	208	188	200	224	220	194	202	190	178	204	192		198.4
MAGNESIO	142	130	104	132	154	128	132	112	146	114	90	88	122	104	110	138	126	146		123.2
SDT	800	710	716.5	723	703	756	772	755	847	787	856	633	675	691	817	878	702	686	1000 MG/L	750.5

AUTORIZÓ:


OFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.


BIOL. OSCAR GUTIERREZ NAVAJA
COORDINADOR DE CALIDAD DEL AGUA



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
DICIEMBRE 2018

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	26	27	28	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	4.5	4.1	3.8	5.0	4.0	5.0	5.0	5.0	4.8	2.0	2.1	1.2	2.4	2.5	3.1	3.6	5.0	4.1	5 NTU.	3.7
P.H.	7.6	7.4	7.5	7.6	7.4	7.2	7.3	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.6	7.6	7.5	7.2	6.5-8.5	7.5
ALCALINIDAD TO	128	120	122	130	122	112	118	126	116	120	116	118	122	120	122	108	124	126		120.6
DUREZA TOTAL	328	330	326	328	324	336	322	328	334	314	314	308	316	306	300	316	330	338	500 MG/LT	322.1
CLORUROS	236	241	244	247	237	210	218	211	215	204	226	211	209	250	202	208	227	221	250 MG/LT	223.2
CLORO RESIDUA	1.2	1.4	1.4	1.3	1.1	1.5	1.3	1.1	1.0	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.4
CALCIO	186	200	222	196	170	208	190	208	188	200	224	220	194	202	190	178	204	192		198.4
MAGNESIO	142	130	104	132	154	128	132	112	146	114	90	88	122	104	110	138	126	146		123.2
SDT	800	710	716.5	723	703	758	772	755	847	787	856	633	675	691	817	878	702	686	1000 MG/LT	750.5

AUTORIZO:


QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.


BIODORO GUILTERMO NAVA LLIZANO
COORDINADOR DE CALIDAD DEL AGUA




TAM
TAMAULIPAS