


PLANTA POTABILIZADORA PASTOR LOZANO  
ANALISIS FISICOQUÍMICOS  
AGUA POTABLE  
dic-17

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	2.9	3.3	3.0	3.5	2.6	1.9	1.9	1.5	1.5	1.5	2.2	1.7	2.3	3.8	1.7	2.7		1.3	1.6	1.8	1.6	5 NTU.	2.2
P.H.	7.6	7.5	7.5	7.4	7.5	7.5	7.6	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4		7.5	7.5	7.5	7.4	6.5-8.5	7.5
ALCALINIDAD TOTAL	144	134	136	128	134	110	135	142	144	146	138	136	130	150	140	142		120	136	112	140		134.9
DUREZA TOTAL	254	260	260	264	262	226	262	278	278	268	270	264	274	278	244	272		256	282	266	286	500 MG/LT	265.2
CLORUROS	175	135	176	166	164	126	169	172	174	169	175	162	174	180	145	179		188	168	170	185	250 MG/LT	167.6
COLOR RESIDUAL	1.5	1.5	1.4	1.3	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5		1.5	1.5	1.5	1.4		1.5
CALCIO	194	170	134	172	184	160	192	186	190	196	194	178	176	170	162	154		230	168	170	206		179.2
MAGNESIO	60	90	126	92	78	66	70	92	88	72	76	86	94	108	122	118		26	116	96	80		87.8
SDT	435	457	437	415	432.5	430	475	452	455	460	440	430	440	440	428	435		487	480	505	520	1000 MG/LT	452.7

Realizó

PA.   
QFB. MIRIAM CAVAZOS GARCIA  
JEFE DE LABORATORIO

Vb. Bc.

  
BIOL. JUAN GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA