

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
ENERO 2019

RESULTADOS EN MG/LT

FECHA	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	NOM- 127/94	PROMEDIO
TURBEDAD N.T.U.	9.6	10.3	13.1	16.8	20.1	22.0	23.2	31.1	34.8	38.5	36.6	31.0	28.8	22.0	27.8	22.7	22.7	19.8	12.7	27.0	14.8	12.0	5 NTU.	22.6
P.H.	7.8	7.8	7.7	7.8	7.7	7.7	7.8	7.9	7.7	7.6	7.7	7.8	7.7	7.7	7.7	7.8	7.8	7.7	7.8	7.8	7.9	7.6	6.5-8.5	7.8
ALCALINIDAD TOTAL	120	124	122	120	116	120	130	130	116	118	114	132	124	114	130	130	118	112	122	118	130	130		122.3
DUREZA TOTAL	280	278	288	280	278	266	270	262	260	278	290	292	290	290	292	280	294	272	272	290	296	288	500 MG/LT	280.3
CLORUROS	172	197	179	163	165	168	165	162	168	168	168	182	173	162	171	165	165	168	167	195	164	181	250 MG/LT	171.3
DUREZA DE CALCIO	180	198	200	180	180	166	166	166	176	190	200	176	190	188	182	182	184	180	180	192	200	192		184.0
D. DE MAGNESIO	100	80	88	80	98	100	104	96	84	88	90	116	100	102	110	98	110	92	92	98	96	96		96.3
SDT	548	542	541	522.5	520	517	513.5	510	508	511	563	519	532	538	533	485	485	485	495	501	492	502	1000 MG/LT	516.5

AUTORIZO:


OPR MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.


BIOLOGO GUILLERMO MAVA LUANO
COORDINADOR DE CALIDAD DEL AGUA

