

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA POTABLE
MARZO 2019

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO	
TURBIEDAD N.T.U.	5.0	5.0	4.9	5.0	5.0	4.9	5.0	5.0	4.8	5.0	4.8	4.8	5.0	5.0	4.8	5.0	5.0	4.0	5.0	5.0	5.0	5.0	4.9
P.H.	7.2	7.3	7.2	7.2	7.6	7.3	7.3	7.2	7.2	7.2	7.2	7.2	7.2	7.4	7.5	7.4	7.2	7.2	7.2	7.2	7.4	6.5-8.5	7.3
ALCALINIDAD TOTAL	114	116	114	116	116	106	114	108	122	116	110	116	118	116	130	124	120	145	132	135			119.4
DUREZA TOTAL	332	322	312	310	322	312	320	324	334	328	340	330	326	314	328	328	336	315	312	328	500 MG/LT		323.6
CLORUROS	221	228	220	223	213	226	242	227	225	224	240	218	240	226	221	240	215	210	226	237	250 MG/LT		226.1
COLORO RESIDUAL	1.1	1.3	1.0	1.1	1.2	1.0	1.5	1.3	1.5	1.5	1.1	1.5	1.5	1.0	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.3
DUREZA DE CALCIO	210	180	206	194	188	166	186	180	206	188	210	204	202	184	174	186	180	184	183	184			189.8
D. DE MAGNESIO	122	142	106	116	134	146	134	144	128	140	130	126	124	130	154	142	156	131	129	142			133.8
SDT	627	568	570	549	544	528	523	667	671	666	672	652	672	583	580	588	518	566	625	570	1000 MG/LT		597.0

AUTORIZO:

QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

BIOLOGO GUILHERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

VorBo.

2 de Abril 2019

*Recibi
02/06/19
J. Casillas*

