

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
MARZO 2019

RESULTADOS EN MG/LT

FECHA	1	4	5	6	7	8	11	12	13	14	15	19	20	21	22	25	26	27	28	29	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	9.3	11.3	12.8	12.1	14.0	12.5	11.8	13.5	15.9	13.8	15.3	13.0	12.0	12.0	13.2	10.8	16.0	11.5	13.8	19.9	5 NTU.	13.2
P.H.	7.6	7.7	7.5	7.5	7.7	7.6	7.7	7.5	7.4	7.8	7.4	7.6	7.8	7.6	7.6	7.6	7.6	7.6	7.7	7.7	6.5-8.5	7.6
ALCALINIDAD TOTAL	136	130	134	134	132	136	130	132	128	136	124	126	130	134	136	136	140	142	142	140		133.9
DUREZA TOTAL	282	272	288	276	280	286	260	284	284	300	306	288	280	274	282	280	278	284	276	272	500 MG/LT	281.6
CLORUROS	177	186	173	163	173	171	181	173	173	180	175	160	166	171	180	177	170	170	178	231	250 MG/LT	176.4
DUREZA DE CALCIO	190	200	196	200	188	186	170	194	200	198	192	190	176	178	186	162	180	182	177	178		186.2
D. DE MAGNESIO	92	72	92	76	92	100	90	90	84	102	114	98	104	96	96	118	92	102	99	94		95.2
SDT	530	457	468	455	436	437	426	540	556	563	552	498	518	462	447	432	426	514	514	498	1000 MG/LT	486.4

AUTORIZO:

CFE. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.

BIOLOGO PATRIENMO NAVAJUANO
COORDINADOR DE CALIDAD DEL AGUA

2 - Abril - 2019
Rubi Sanchez

Recabi
02/06/19
- Conds.

