

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
ABRIL 2019

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	22	23	24	25	26	29	30	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	9.1	10.4	9.0	10.2	9.3	7.2	8.5	9.3	13.0	11.7	20.7	29.2	26.3	42.1	45.2	67.3	65.8	68.0	58.2	58.1	5 NTU.	28.9
P.H.	7.8	7.9	7.7	7.8	7.7	7.8	7.8	7.7	7.7	7.6	7.7	7.6	7.8	7.7	7.7	7.7	7.7	7.7	7.6	7.7	6.5-8.5	7.7
ALCALINIDAD TOTAL	130	160	168	170	180	178	170	162	166	170	164	170	168	142	150	130	120	144	142	150		156.7
DUREZA TOTAL	390	404	334	326	312	306	288	312	284	288	258	244	260	236	282	254	268	248	252	280	500 MG/LT	290.3
CLORUROS	144	113	160	122	130	131	114	122	138	130	124	125	129	103	223	162	170	194	98	210	250 MG/LT	142.1
DUREZA DE CALCIO	260	254	220	196	198	228	204	208	212	188	176	178	180	156	182	108	116	168	174	160		188.3
D. DE MAGNESIO	130	150	114	130	114	78	84	104	72	100	82	66	80	80	100	146	152	80	78	100		102.0
SDT	831	1077	896	959	835	976	841	906	825	568	503	454	734	439	434	370	377	372	376	482	1000 MG/LT	662.8

AUTORIZO:

QEB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.

BIOLOGO SILLERMO NAVAJUANO
COORDINADOR DE CALIDAD DEL AGUA

