

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
MAYO2019

RESULTADOS EN MG/LT

FECHA:	2	3	6	7	8	9	13	14	15	16	17	20	21	22	23	24	27	28	29	30	31	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	78.2	54.0	59.9	59.2	48.1	50.6	48.3	46.1	87.6	53.2	29.8	30.6	30.0	27.8	30.7	39.8	14.9	11.0	12.5	29.8	29.8	5 NTU.	41.5
P.H.	7.6	7.5	7.8	7.5	7.6	7.8	7.4	7.5	7.7	7.6	7.4	7.7	7.5	7.9	7.7	7.6	7.6	7.5	7.1	7.7	7.5	6.5-8.5	7.6
ALCALINIDAD TOTA	156	154	158	164	142	144	164	140	174	156	164	168	170	174	172	160	152	144	146	162	164	158.5	158.5
DUREZA TOTAL	258	258	242	260	240	240	264	256	256	274	276	302	440	300	286	278	242	262	268	256	252	500 MG/LT	271.9
CLORUROS	105	101	101	103	112	120	101	135	101	105	238	170	248	166	168	170	151	132	153	158	162	250 MG/LT	142.9
DUREZA DE CALCIO	178	176	178	176	170	176	182	170	168	198	188	202	244	194	204	184	178	170	194	174	172	184.6	184.6
D. DE MAGNESIO	80	82	64	84	70	64	82	86	88	76	88	100	196	106	82	94	64	92	74	82	80	87.3	87.3
SDT	486	503	513	478	446	446	508	594	588	598	621	659	817	598	645	583	688	656	671	560	538	1000 MG/LT	580.8

AUTORIZO:

P.4. 
C.F.B. MIRIAM GAYZOS GARCIA
RESPONSABLE DE LABORATORIO



Vo.Bo. 



Recibido
04/06/19
8:53am