


PLANTA POTABILIZADORA PASTOR LOZANO
ANALISIS FISICOQUÍMICOS
AGUA POTABLE
feb-17

RESULTADOS EN MG/LT


FECHA:	1	2	3	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	5.0	4.9	4.9	4.7	5.0	5.0	4.7	5.0	5.1	4.2	3.9	4.0	3.1	4.5	5.3	4.7	4.8	5.0	5 NTU.	4.7
P.H.	7.4	7.6	7.7	7.4	7.7	7.6	7.6	7.4	7.6	7.6	7.6	7.7	7.8	7.6	7.8	7.6	7.6	7.7	7.6	6.5-8.5	7.6
ALCALINIDAD TOTAL	126	130	116	114	116	128	118	120	124	120	138	130	110	120	122	128	114	106	100		120.0
DUREZA TOTAL	310	320	310	296	330	348	314	308	336	344	354	348	304	334	316	336	286	302	306	500 MG/LT	321.2
CLORUROS	175	180	175	190	170	195	186	174	212	174	190	180	168	170	165	160	174	182	172	250 MG/LT	178.5
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4		1.5
CALCIO	210	220	196	174	210	198	210	222	212	200	200	218	160	210	182	180	140	177	232		197.3
MAGNESIO	100	100	114	122	120	150	104	86	124	144	154	132	144	124	134	156	146	125	74		123.8
SDT	542	533	540	531	534	593	561	529	559	576	575	577	529	537	544	522	519	521	520	1000 MG/LT	544.3

Realizó



MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO

Vo. Bo.



BIOL. JUAN GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA