


PLANTA POTABILIZADORA PASTOR LOZANO  
ANALISIS FISICOQUÍMICOS  
AGUA CRUDA  
mar-18

RESULTADOS EN MG/LT


FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	20	21	22	23	26	27	28	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	11.6	10.3	7.7	8.5	13.4	11.3	10.5	13.6	12.4	11.3	11.8	12.3	11.2	12.0	13.8	17.3	44.0	39.5	40.0	5 NTU.	16.4
P.H.	7.8	7.8	7.8	7.9	7.5	7.9	7.9	7.6	8	7.5	7.9	8	7.9	7.8	7.9	7.8	7.6	7.6	7.8	6,5-8,5	7.8
ALCALINIDAD TOTAL	96	110	104	104	108	112	110	92	82	86	98	94	92	76	96	82	94	94	98		96.2
DUREZA TOTAL	274	280	274	284	272	268	272	270	282	292	210	256	270	210	240	196	250	268	296	500 MG/LT	261.3
CLORUROS	134	160	132	150	135	138	130	115	128	128	125	132	133	111	120	96	115	126	122	250 MG/LT	127.9
CALCIO	210	168	184	138	182	124	184	174	194	148	40	110	146	64	82	62	120	44	142		132.4
MAGNESIO	96	110	90	146	90	144	88	96	88	144	170	146	124	146	150	134	130	224	154		130.0
SDT	554	574	547	538	528	493	507	473	468	448	435	433	412	401	400	401	409	414	411	1000 MG/LT	465.6

Realizó



QFB. MIRIAM CAVAZOS GARCÍA  
JEFE DE LABORATORIO

Vo. Bo.



BIOL. JUAN GUILLERMO NAVA LUJANO

