

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA  
JULIO 2019

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	NOM-127/94	PROMEDIO
TURBIDEZ N.T.U.	7.6	9.8	11.1	8.6	8.9	8.9	11.3	12.5	9.8	10.5	12.5	14.1	12.10	13.9	12.1	16.5	18.5	18.7	16.8	18.2	14.5	14.5	15.6	5 NTU.	12.9
P.H.	7.4	7.3	7.8	7.3	7.4	7.4	7.3	7.5	7.2	7.3	7.4	7.1	7.5	7.2	7.1	7.2	7.6	7.2	7.6	7.5	7.5	7.3	7.6	6.5-9.5	7.4
ALCALINIDAD TOTAL	154	148	150	164	170	160	168	170	180	160	130	148	144	176	140	160	165	162	148	134	148	150	164		156.2
DUREZA TOTAL	246	322	234	260	270	320	292	330	316	300	220	200	240	240	220	240	236	240	228	240	230	220	244	500 MG/L	256.0
CLORUROS	195	225	198	190	191	240	210	230	245	280	163	155	162	165	165	170	180	160	190	150	150	142	158	250 MG/L	187.6
DUREZA DE CALCIO	166	192	168	160	180	190	200	190	180	170	144	160	168	150	156	144	152	140	150	154	144	140	142		162.6
D. DE MAGNESIO	80	130	66	100	90	130	92	140	136	130	76	60	72	90	64	96	84	100	78	86	86	80	102		94.3
SDT	445	579	540	557.5	810	615	991	859.5	779.5	654.5	555	536	522.5	540	512	531.5	767	994.5	736.5	437	439	434	451	1000 MG/LT	621.2

AUTORIZO:

*[Signature]*  
QFB. MIRIAM CAVAZOS GARCIA  
RESPONSABLE DE LABORATORIO

*[Signature]*  
Vó.Bo.  
BIÓLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA



*Jona & Damm*  
*13/8/2019*



*[Signature]*  
Lic. Miriam Cavazos  
9:31am  
13/AGOSTO