



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS
AGUA CRUDA
DICIEMBRE 2019

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	26	27	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	9.8	14.3	13.2	10.4	3.4	12.9	14.1	13.2	14.0	12.0	10.2	12.0	11.2	12.6	13.5	12.5	12.8	11.6	13.1	10.3	5 NTU.	11.9
P.H.	7.5	7.7	8.1	7.5	7.3	7.7	7.7	7.7	7.9	7.9	7.9	7.8	7.7	7.8	7.9	8.0	7.7	7.8	7.8	7.1	6.5-8.5	7.7
ALCALINIDAD TOTAL	136	134	152	178	154	148	150	140	132	124	128	122	154	148	143	150	126	138	134	174		143.3
DUREZA TOTAL	314	272	258	280	280	280	262	280	360	300	296	256	308	286	280	308	252	300	270	310	500 MG/LT	286.6
CLORUROS	195	153	180	165	197	195	180	187	230	175	199	193	170	160	160	167	170	180	192	194	250 MG/LT	182.1
DUREZA DE CALCIO	150	152	200	160	160	210	160	210	192	204	172	112	202	210	200	268	180	186	172	216		185.8
D. DE MAGNESIO	165	120	80	120	120	70	102	50	168	96	124	144	106	76	80	40	72	114	98	94		102.0
SDT	543	539	512	489.5	506	544	519.5	500.5	657	632	651	580	573	545.5	537	540	567.5	561.5	566	596	1000 MG/LT	558.0



Vo. Bo.
BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA