



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS
AGUA POTABLE
FEBRERO 2020

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	3.8	2.7	2.5	3.6	4.4	4.3	2.1	4.7	4.0	4.4	4.2	2.5	3.6	2.3	2.5	2.7	2.4	4.8	3.2	3.3	5 NTU	3.4
P.H.	7.0	6.9	6.9	7.4	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.1	7.1	7.1	7.2	7.0	7.3	7.0	7.1	6.5-8.5	7.1
ALCALINIDAD TOTAL	139	120	123	140	138	126	140	138	128	132	142	136	132	134	134	130	130	136	134	136		133.4
DUREZA TOTAL	313	440	296	324	330	242	240	300	364	310	254	308	300	338	364	344	356	360	368	340	500 MG/LT	324.6
DUREZA DE CALCIO	168	360	200	208	206	180	170	190	200	200	180	196	194	190	198	204	208	206	230	212		205.0
D. DE MAGNESIO	145	80	96	116	124	62	70	110	164	110	74	112	106	148	166	140	148	154	138	128		119.6
CLORUROS	94	250	220	210	205	208	220	205	195	193	180	190	172	174	182	172	190	198	190	212	250 MG/LT	193.0
CLORO RESIDUAL	1.5	1.6	2.1	1.7	1.3	1.8	1.6	1.7	2.2	0.8	2.0	1.9	1.7	2.2	1.8	1.5	0.9	1.7	1.8	1.5		1.6
SDT	687	674.5	642	660	623	567	537	605	734	733	723	825	651	696	627	679	674	617	733	652	1000 MG/LT	667.0

AUTORIZO:

QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DEL LABORATORIO

Vo.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

