

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS
AGUA CRUDA
FEBRERO 2020



RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	NOM 127/94	PROMEDIO
TURBIEDAD N.T.U.	8.8	11.5	14.5	12.8	12.3	13.6	12.8	11.6	4.3	10.7	13.8	10.5	11.3	9.7	11.8	14.0	14.8	16.0	8.7	12.5	5 NTU.	11.8
P.H.	7.4	7.5	7.6	7.3	7.3	7.5	7.4	7.5	7.3	7.6	7.4	7.7	7.6	7.7	7.6	7.5	7.5	7.5	7.6	7.5	6.5-8.5	7.5
ALCALINIDAD TOTAL	132	132	134	130	132	134	156	146	140	144	140	142	138	140	146	148	144	144	148	154		141.2
DUREZA TOTAL	248	380	260	290	294	234	220	286	294	300	236	295	292	310	338	338	312	332	338	338	500 MG/LT	296.8
DUREZA DE CALCIO	106	290	180	164	180	170	165	184	210	204	166	190	194	224	200	260	200	212	224	248		198.6
D. DE MAGNESIO	142	90	80	126	114	64	55	102	84	96	70	105	98	86	138	78	112	120	114	90		98.2
CLORUROS	95	230	188	190	196	195	205	192	180	182	172	185	160	193	171	178	172	184	183	208	250 MG/LT	183.0
SDT	607	610	592	586	567	560	536	604	742	748	712	821	658	695	622	673	672	626	752	658	1000 MG/LT	652.1

AUTORIZO:

QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

