



AYUNTAMIENTO
REYNOSA
2018 - 2021



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS AGUA POTABLE ABRIL 2020

RESULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	13	14	15	16	17	20	21	22	23	24	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	5.0	5.0	5.0	5.0	4.8	5.0	5.0	3.0	4.3	2.8	5.0	5.0	5.0	4.6	3.2	3.0	5.0	5.0	5.0	5 NTU.	4.5
P.H.	7.4	7.5	7.6	7.4	7.5	7.4	7.3	7.4	7.2	7.4	7.3	7.3	7.2	7.3	7.3	7.4	7.5	7.4	7.4	6.7	6,5-8,5	7.3
ALCALINIDAD TOTAL	102	106	102	108	104	110	116	116	102	110	104	136	138	140	128	124	126	136	126	130		118.2
DUREZA TOTAL	310	342	308	338	350	342	314	332	342	352	366	350	314	320	360	328	346	396	400	386	500 MG/LT	344.8
DUREZA DE CALCIO	206	212	194	208	206	194	214	220	200	214	224	240	162	196	222	212	224	210	220	218		209.8
D. DE MAGNESIO	104	130	114	130	144	148	100	112	142	138	142	110	152	124	138	116	122	186	180	168		135.0
CLORUROS	250	206	189	185	223	217	192	209	219	196	225	230	200	218	218	226	208	225	190	200	250 MG/LT	211.3
CLORO RESIDUAL	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.4	1.4	1.5	1.3		1.5
SDT	596	613	593.5	401	612.0	694	637	744	736	550	829	564	768	736	701	686	680	720	691	694	1000 MG/LT	662.3
TEMPERATURA oC	23.9	26.5	25.1	23.2	24.5	25	24.3	23	21.2	21.1	22.8	26.6	27.4	26.3	26.4	26.7	26.6	27.5	27.1	25.8		25.05

AUTORIZÓ:

QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Biólogo GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

