


PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
ABRIL 2020


RESULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	13	14	15	16	17	20	21	22	23	24	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	56.9	43.4	39.5	30.3	30.7	32.1	18.5	20.5	16.1	14.8	18.8	11.1	10.9	14.1	11.2	11.6	11.3	15.8	12.3	12.0	5 NTU.	21.6
P.H.	7.8	7.9	8.0	7.9	8.0	7.8	7.9	7.8	7.9	7.8	7.8	7.9	7.9	7.8	7.9	7.8	7.9	7.8	7.9	7.8	6,5-8,5	7.9
ALCALINIDAD TOTAL	102	110	108	120	114	112	120	110	116	124	120	118	144	138	132	132	132	136	134	138		123.0
DUREZA TOTAL	320	308	300	308	316	322	290	304	300	300	342	326	298	310	336	358	360	386	340	360	500 MG/LT	324.2
DUREZA DE CALCIO	182	186	192	196	182	182	200	200	216	202	208	223	150	180	244	224	212	206	210	210		200.3
D. DE MAGNESIO	138	122	108	112	134	140	90	104	84	98	134	103	148	130	92	134	148	180	130	150		124.0
CLORUROS	250	250	174	165	185	186	162	190	181	185	190	185	190	200	236	215	230	218	180	190	250 MG/LT	198.1
SDT	548	547	556.5	566	564	538	609	697	705	531	794	554	754	718	690	698	724	670	644	634	1000 MG/LT	637.1
TEMPERATURA °C	23.7	24.8	25	22.4	23.8	24.3	24.4	23.8	21.6	21.1	22.4	25.8	25.6	25.9	25.8	26.8	25.8	27.1	26.9	25.6		24.6

AUTORIZÓ:


QFB MIRIAM CAVARES GARCIA
RESPONSABLE DE LABORATORIO



Vo.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA