

PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
MAYO 2020

RESULTADOS EN MG/LT

FECHA:	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	16.3	15.5	16.7	22.3	16.3	20.2	22.8	16.2	12.6	12.5	17.2	17.5	18.9	9.9	12.0	9.8	11.8	33.2	95.5	38.6	5 NTU.	21.8
P.H.	7.4	7.7	7.7	7.1	7.7	7.3	7.3	7.6	7.2	7.6	7.6	7.6	7.7	7.7	7.8	7.6	7.5	7.5	7.4	7.5	6.5-8.5	7.5
ALCALINIDAD TOTAL	132	132	134	116	128	126	130	130	126	140	132	128	140	130	136	144	146	140	100	104		129.7
DUREZA TOTAL	288	294	326	390	380	320	338	320	310	380	358	310	436	406	460	466	460	480	322	288	500 MG/LT	366.6
DUREZA DE CALCIO	220	206	232	278	274	218	210	218	210	244	224	200	272	300	282	296	340	302	200	188		245.7
D. DE MAGNESIO	68	88	94	112	106	102	128	102	100	136	134	110	164	106	178	170	120	178	122	100		120.9
CLORUROS	210	195	197	203	194	210	207	219	204	223	174	208	202	191	219	244	247	250	142	140	250 MG/LT	204.0
SDT	638	522	656	655	659	713	724	749	723	738	673	684	663	743	764	1032	755.5	689	372.5	480.4	1000 MG/LT	681.7
TEMPERATURA °C	26.4	26.8	27.2	26.5	26.7	25.1	25.7	25.7	26.2	27	26.4	27.3	27.8	27.9	27.8	27.3	27.7	27.8	27.1	26.5		26.8

AUTORIZÓ:


 QFE MIRIAM CAVAZOS GARCÍA
 RESPONSABLE DE LABORATORIO

Vo.Bo.

 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA