

PLANTA POTABILIZADORA PASTOR LOZANO

**ANALISIS FISICOQUÍMICOS
AGUA POTABLE
JUNIO 2020**

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	5.0	5.0	5.0	5.0	4.7	4.4	5.0	5.0	5.0	3.0	3.2	3.7	3.9	3.7	3.8	4.0	3.9	4.1	3.8	3.6	5.0	5 NTU.	4.3
P.H.	7.6	7.4	7.3	7.3	7.3	7.3	7.5	7.5	7.4	7.6	7.1	7.5	7.5	7.4	7.4	7.3	7.2	7.4	7.5	7.5	7.4	7.5	6,5-8,5	7.4
ALCALINIDAD TOTAL	88	102	124	122	104	132	126	116	120	122	142	138	112	128	122	130	134	126	134	134	122	110		122.2
DUREZA TOTAL	380	444	490	400	360	420	436	420	430	406	440	452	406	412	400	316	356	370	372	380	310	280	500 MG/LT	394.5
DUREZA DE CALCIO	280	310	320	310	246	270	250	268	310	300	226	270	262	250	220	212	220	222	240	250	200	200		256.2
D. DE MAGNESIO	100	134	170	90	114	150	186	152	120	106	214	182	144	162	180	104	136	148	132	130	110	80		138.4
CLORUROS	182	216	247	191	243	250	248	250	248	250	250	250	250	250	230	250	246	240	250	240	162	250	250 MG/LT	236.0
CLORO DE RESIDUAL	1.2	1.5	1.0	1.4	1.5	1.2	1.0	1.1	1.2	1.1	1.0	1.2	1.1	1.3	1.2	1.5	1.5	1.5	1.2	1.3	1.5	1.1		1.3
SDT	473	810	753	735	855	889	992	980	795	743	881	983	852	709	649	600	599	608	634	621	583	717	1000 MG/LT	748.2
TEMPERATURA °C	23.5	25.8	27.2	28.3	26.5	30.0	30.0	29.7	27.7	29.2	29.1	29.1	28.0	28.0	29.6	29.3	29.3	29.4	28.8	28.7	29.0	28.7		28.4

AUTORIZÓ:

QFB. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA