


PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA AGUA DEL RÍO BRAVO
AGOSTO 2020


RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	22.1	17.3	13.5	12.3	14.0	12.2	16.8	20.8	17.6	16.8	15.6	14.0	19.7	13.6	16.8	14.9	15.5	27.8	15.5	16.5	18.0	5 NTU	16.7
P.H.	7.1	7.1	7.3	7.3	7.2	7.1	7.4	7.4	7.5	7.4	7.8	7.9	7.8	7.5	7.4	7.7	7.8	7.5	7.6	7.6	7.4	6.5-8.5	7.5
ALCALINIDAD TOTAL	140	140	138	148	148	146	146	154	160	160	168	160	156	146	130	120	149	112	102	100	100		139
DUREZA TOTAL	300	316	312	310	290	288	324	380	360	360	396	420	416	460	446	400	360	372	380	384	366	500	367
DUREZA DE CALCIO	206	210	220	220	200	200	236	280	262	276	290	320	310	294	280	260	260	262	232	226	224		250
D. DE MAGNESIO	94	106	92	90	90	88	88	120	98	120	130	100	106	166	166	140	100	110	148	158	142		117
CLORUROS	143	168	250	250	242	235	237	245	280	300	500	400	420	422	395	320	307	274	255	242	223	250	291
SDT	483	619	650	678	721	730	750	892	900	911	1247	1412	1490	1283	1174	1054	980	805	746	746	771	1000	907
TEMPERATURA °C	28	27	27	29	28	28	29	29	27	26	28	28	28	28	28	28	29	28	29	29	28		28

AUTORIZÓ:


OF. MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO

Vo.Bo.


BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA