


PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA AGUA DEL RIO BRAVO
SEPTIEMBRE 2020

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	17	18	21	22	23	24	25	28	29	30	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	15.0	29.7	17.8	20.7	20.1	18.8	23.0	20.0	20.8	16.8	19.0	18.0	18.3	21.2	18.1	19.9	17.1	14.2	16.5	20.5	23.6	5 NTU.	20
P.H.	7.4	7.3	7.4	7.7	7.4	7.4	7.5	7.4	7.4	7.4	7.6	7.2	7.3	7.2	7.3	7.3	7.3	7.6	7.2	7.2	7.4	6.5-8.5	7.4
ALCALINIDAD TOTAL	116	102	126	120	122	110	110	110	120	126	124	120	140	130	134	124	124	116	114	130	126		121
DUREZA TOTAL	384	348	330	312	310	305	310	310	320	330	344	336	370	396	400	380	376	368	374	390	376	500 MG/LT	349
DUREZA DE CALCIO	240	204	158	164	198	180	196	190	168	240	220	212	238	260	252	224	240	218	220	258	220		213
D. DE MAGNESIO	144	144	172	148	112	125	114	120	152	90	124	124	132	136	148	156	136	150	154	132	156		136
CLORUROS	264	211	190	180	170	180	178	184	190	200	200	204	250	286	283	266	265	265	329	321	294	250 MG/LT	232
SDT	853	629	606	632	607	559	549	626	650	700	659	865	635	912	940	861	812	791	1000	957	928	1000 MG/LT	746
TEMPERATURA °C	28	28	29	28	28	27	28	25	25	27	28	26	25	24	26	26	26	26	26	26	25		26

AUTORIZO:


QFB MIRIAM ZAVAZOS GARCIA
RESPONSABLE DE LABORATORIO


BETO OSORIO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA