

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA AGUA DEL RIO BRAVO
NOVIEMBRE 2020

RESULTADOS EN MG/L

FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	PROMEDIO
TURBIDEZ N.T.U.	14.3	13.8	13.2	12.4	11.8	11.0	11.6	11.2	10.8	11.0	11.3	10.9	12.7	12.8	12.2	12.9	12.1	12.3	12.0	12.3	12
P.H.	7.1	7.3	7.3	7.5	7.8	7.0	7.1	7.3	7.1	7.6	7.3	7.5	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.3	7.3
ALCALINIDAD TOTAL	130	128	130	138	132	136	138	134	132	136	130	128	124	130	132	132	133	136	140	136	133
DUREZA TOTAL	322	340	330	340	328	316	320	317	336	334	336	322	334	324	338	330	334	338	336	338	331
DUREZA DE CALCIO	215	225	220	240	212	214	212	215	226	230	230	210	204	204	220	200	215	225	230	180	216
D. DE MAGNESIO	107	115	110	100	116	102	108	102	110	104	106	112	130	120	118	130	119	113	109	158	115
CLORUROS	169	172	178	175	170	178	180	180	186	195	181	173	185	181	174	180	180	179	182	181	179
SDT	700	713	710	740	702	690	678	646	623	608	600	610	669	561	527	572	565	583	600	622	633
TEMPERATURA °C	22	22	21	22	22	24	24	24	24	24	23	22	23	23	23	24	23	24	24	22	23

AUTORIZO:


OEB. MARIAM CAYAZOS GARCIA
RESPONSABLE DE LABORATORIO


BIOLOGO GUILTERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

Vc Bo