

PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS


AGUA POTABLE
DICIEMBRE 2020

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	28	29	30	NOM- 127/94	PROMEDIO
TURBIDEZ N.T.U.	5.0	4.8	5.0	4.9	4.8	5.0	5.0	4.6	4.2	4.9	4.6	5.0	5.0	4.7	4.9	5.0	5.0	4.8	5.0	5.0	5 NTU.	4.9
P.H.	7.4	7.4	7.5	7.6	7.6	7.6	7.8	7.4	7.8	7.7	7.3	7.5	7.3	7.7	7.6	7.3	7.4	7.5	7.4	7.7	6.5-8.5	7.5
ALCALINIDAD TOTAL	138	140	138	138	140	144	148	152	156	160	164	160	162	156	148	137	130	122	148	152		146.7
DUREZA TOTAL	380	390	432	456	412	400	452	454	454	456	450	460	461	456	442	425	427	378	376	370	500 MG/LT	426.6
DUREZA DE CALCIO	250	246	272	276	280	280	330	328	330	335	332	331	327	316	308	305	306	260	250	232		294.7
D. DE MAGNESIO	130	144	160	180	132	120	122	126	124	121	118	129	134	140	134	120	121	118	126	138		131.9
CLORUROS	250	248	250	240	238	246	250	234	247	250	248	250	250	250	205	210	196	225	214	236	250 MG/LT	236.8
COLOR DE RESIDUAL	1.5	1.5	1.4	1.4	1.3	1.5	1.5	1.5	1.4	1.5	1.4	1.4	1.5	1.5	1.5	1.5	1.4	1.2	1.4	1.5	0.2-1.5 MG/LT	1.4
SDT	854	876	974	952	947	989	958	944	976	985	988	997	998	961	889	850	820	620	578	788	1000 MG/LT	897.2
TEMPERATURA °C	20	20	19	18	17	17	17	18	19	18	17	17	17	18	19	19	20	19	20	20		18.4

AUTORIZO:


OFE MIRIAM CAVAZOS GARCIA
RESPONSABLE DE LABORATORIO


BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA