

PLANTA POTABILIZADORA PASTOR LOZANO
ANALISIS FISICOQUIMICOS
AGUA CRUDA
abr-18

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	38.4	48.6	51.7	59.8	53.2	44.9	44.0	44.5	38.0	29.0	24.0	23.0	23.0	23.0	27.5	31.2	33.4	41.3	38.6	34.2	24.3	5 NTU.	36.9
P.H.	7.5	7.9	7.6	7.6	7.7	7.7	7.8	8	7.7	7.8	7.8	7.8	8	7.8	7.8	7.8	7.8	7.9	8.1	8	7.7	6.5-8.5	7.8
ALCALINIDAD TOTAL	86	90	80	78	90	100	90	92	90	86	97	88	90	96	90	90	80	82	86	84	66		87.2
DUREZA TOTAL	240	260	260	266	280	266	264	268	274	290	290	248	260	282	260	260	216	230	270	280	224	500 MG/LT	261.3
CLORUROS	110	112	98	130	140	150	130	136	140	120	135	120	140	140	146	140	120	130	120	120	120	250 MG/LT	128.4
CALCIO	170	176	180	190	180	190	190	200	210	190	196	180	190	190	160	190	148	160	140	160	178		179.4
MAGNESIO	70	84	80	76	100	76	74	68	64	100	94	68	70	92	100	70	68	70	130	120	46		81.9
SDT	427	467	470	476	468	475	475	486	487	502	481	483	481	480	458	460	449	446	452	447	462	1000 MG/LT	468.2

Realizó

Miriam Cavazos Garcia
DRA. MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO



Guillermo Nava Lujano
Vg. Bo.
BIROTECAN GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

