

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
Jun-18

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM- 127/94	PROMEDIO	
TURBIEDAD N.T.U.	4.5	5.0	5.0	4.9	5.0	4.9	5.0	5.0	5.0	5.0	5.0	5.0	4.9	4.8	4.9	4.9	5.0	5.0	5.0	5.0	5.0	5.0	5.0	4.9
P.H.	7.3	7.2	7.2	7.6	7.4	7.4	7.3	7.1	7.4	7.3	7.3	7.3	7.3	7.2	7.1	7.2	6.8	6.7	6.8	6.8	6.8	7.0	6.5-8.5	7.2
ALCALINIDAD TOTAL	96	92	98	88	88	90	80	106	100	90	106	86	104	90	94	80	86	90	88	100	92		92.6	
DUREZA TOTAL	342	328	306	328	324	306	280	312	318	390	310	292	310	330	276	250	222	220	220	264	288	500 MG/LT	295.5	
CLORUROS	220	210	203	215	200	216	177	211	194	249	194	206	205	201	193	173	150	137	159	183	225	250 MG/LT	196.2	
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.3	1.1	1.4	1.5	1.5	1.5	0.9	1.3	0.9	0.9	1.5	1.5	1	1.5	1.5	1.4		1.3	
CALCIO	160	150	128	156	158	158	160	136	140	208	130	160	192	166	166	162	140	152	152	164	144		156.3	
MAGNESIO	182	178	178	172	166	148	120	176	178	174	180	132	118	164	110	88	82	68	69	64	144		137.6	
SDT	650	599	563	574	542	690	638	562	572	553	620	612	475	405	585	484	414	409	403	467	610	1000 MG/LT	543.7	

Realizó
05/18/18
A.S.

Realizó
OEB MIRIAM CAVAZOS GARCÍA
JEFE DE LABORATORIO

Yo. Bp.
BIO. JUAN GUILTERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

