



AYUNTAMIENTO
REYNOSA
2018 - 2021



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS AGUA CRUDA RIO BRAVO ABRIL 2021

RESULTADOS EN MG/LT

FECHA:	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	26	24	21	21	20	22	23	20	22	23	20	21	22	24	22	22	25	28	23	22	22
P.H.	7.4	7.4	7.3	7.1	7.5	7.4	7.5	7.4	7.4	7.4	7.4	7.5	7.5	7.3	7.4	7.4	7.5	7.5	7.4	7.6	7.4
ALCALINIDAD TOTAL	126	120	128	132	126	127	130	130	128	130	128	124	114	120	132	136	118	115	112	122	125
DUREZA TOTAL	332	320	300	298	302	310	302	304	314	328	316	312	324	302	322	314	316	320	328	330	315
DUREZA DE CALCIO	226	210	200	196	198	200	190	180	188	204	188	186	190	166	185	190	200	190	194	192	194
D. DE MAGNESIO	106	110	100	102	104	110	112	124	126	124	128	126	134	136	137	124	116	130	134	138	121
CLORUROS	156	169	167	162	166	170	180	187	186	183	180	175	181	185	188	182	185	192	188	190	179
SDT	622	700	750	700	620	690	700	779	792	863	790	600	552	565	640	650	676	667	638	665	683
TEMPERATURA °C	21.6	21.9	23.3	24.0	24.8	26.4	26.1	25.7	26.4	25.9	22.5	21.8	22.3	22.8	23.8	26.3	26.0	25.9	26.8	26.1	25

AUTORIZÓ:

Va.Bo.

I.Q. BERENICE LOPEZ MELGAR
RESPONSABLE DE LABORATORIO

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA