



AYUNTAMIENTO
REYNOSA
2018 - 2021



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS AGUA POTABLE MAYO 2021

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	4.8	4.5	5.0	4.8	4.8	5.0	5.0	4.5	5.0	4.8	5.0	5.0	4.7	4.2	4.6	4.9	4.7	4.5	4.7	5.0	5 NTU	4.8
P.H.	7.0	7.3	7.0	7.0	7.1	7.0	7.2	7.0	7.3	7.0	7.1	7.0	7.1	7.3	7.4	7.0	7.1	7.7	7.0	7.2	7.5	6,5-8,5	7.2
ALCALINIDAD TOTAL	128	122	128	126	122	126	135	122	130	138	130	118	110	118	134	116	117	120	126	124	128		125
DUREZA TOTAL	330	336	328	336	334	326	336	344	342	336	320	334	336	326	310	316	320	338	330	380	387	500 MG/LT	335
DUREZA DE CALCIO	176	214	210	224	210	200	205	208	210	200	180	190	194	180	177	180	190	196	180	234	238		200
D. DE MAGNESIO	154	122	118	112	124	126	131	136	132	136	140	144	142	146	133	136	130	142	150	146	149		136
CLORUROS	202	210	208	210	215	220	218	220	218	228	226	230	220	239	202	200	202	204	201	220	200	250 MG/LT	214
CLORO RESIDUAL	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.5		1.5
SDT	675	680	690	698	685	694	696	660	625	675	610	685	642	723	806	757	725	700	780	800	810	1000 MG/LT	706
TEMPERATURA °C	26.5	27.4	27.2	26.2	26.1	28.1	27.9	27.2	26.2	26.2	26.8	26.5	27.1	23.9	25.7	27.8	28.0	28.3	27.7	28.8	27.7		27

AUTORIZÓ:

I.Q. BERENICE LOPEZ MELGAR
RESPONSABLE DE LABORATORIO

Vo.Bo.
BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA