

PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
Jun-18

RESULTADOS EN MG/LIT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	19.3	17.3	16.3	16.9	17.3	16.0	17.4	16.0	13.4	14.2	17.8	16.1	21.0	18.2	15.2	400.0	64.1	40.1	17.7	10.3	12.3	5 NTU.	37.9
P.H.	7.6	7.8	7.4	7.7	7.5	7.6	7.6	7.5	7.8	7.8	7.5	7.6	7.6	7.5	7.8	7.6	7.1	6.9	6.9	7.5	7.2	6.5-8.5	7.5
ALCALINIDAD TOTAL	82	88	84	90	80	80	80	106	100	104	104	86	108	98	80	74	80	84	86	100	108		90.5
DUREZA TOTAL	282	240	268	280	270	264	260	252	260	314	252	236	242	310	250	242	160	172	190	214	228	500 MG/LIT	247.0
CLORUROS	173	141	145	154	150	156	140	140	147	199	151	176	179	197	158	155	87	88	106	140	171	250 MG/LIT	150.1
CALCIO	156	108	122	166	160	140	150	100	150	138	132	132	152	176	146	134	110	118	154	160	164		141.3
MAGNESIO	126	132	146	114	110	124	110	152	110	176	120	104	90	144	104	108	50	54	36	54	64		106.1
SDT	580	514	486	480	451	504	538	462	464	460	520	515	449	424	486	502	281	282	338	402	501	1000 MG/LIT	459.0

Realizó

SEB. MIRIAM CAJAZOS GARCIA
JEFE DE LABORATORIO

Vo. Bo.
BIOS. JUAN GUILLERMO NAVAJUANO
COORDINADOR DE CALIDAD DEL AGUA

Revisado
05/06/18
García

