



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUÍMICOS
AGUA CRUDA RIO BRAVO
JULIO 2021

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	28.1	25.2	20.0	24.8	36.1	36.7	37.1	30.1	37.9	25.6	18.4	23.8	22.4	18.1	16.8	23.2	21.3	14.5	22.3	15.1	13.1	15.3	24
P.H.	7.1	7.1	7.0	7.5	7.0	7.1	7.0	6.8	7.1	7.1	7.3	7.4	7.1	7.0	6.8	7.0	7.0	7.6	7.7	7.3	7.4	7.4	7.2
ALCALINIDAD TOTAL	120	124	114	106	112	100	88	130	138	140	144	148	150	148	134	140	142	160	160	146	152	146	134
DUREZA TOTAL	294	286	274	300	296	248	240	292	306	314	324	336	380	370	368	358	360	480	350	454	436	440	341
DUREZA DE CALCIO	162	158	144	160	200	168	160	164	176	180	192	198	200	198	194	196	200	314	180	232	252	218	193
D. DE MAGNESIO	132	128	130	140	96	80	80	128	130	134	132	138	180	172	174	162	160	166	170	222	184	222	148
CLORUROS	160	158	155	166	194	164	140	191	217	223	234	285	316	340	360	350	360	360	365	370	370	376	266
SDT	586	596	560	504	332	549	395	598	776	718	810	940	1235	1212	1183	1000	1100	1015	1196	1210	1404	1310	874
TEMPERATURA °C	27.8	28.1	29.5	29.1	26.1	26.1	27.6	28.8	27.9	27.9	27.8	28.0	29.0	28.8	28.8	27.0	26.6	28.9	29.4	29.4	28.7	29.0	28

AUTORIZÓ:

Vo.Bo.

I.Q. BERENICE LOPEZ MELGAR
RESPONSABLE DE LABORATORIO

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA