



GOBIERNO MUNICIPAL DE  
**REYNOSA**  
ADMINISTRACIÓN 2021 - 2024

**COMAPA**  
REYNOSA



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA POTABLE  
FEBRERO 2022

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	NOM-127/84	PROMEDIO
TURBIEDAD N.T.U.	4.9	5.0	4.9	4.7	4.9	4.0	4.8	4.8	4.9	5.0	4.8	4.7	4.9	4.5	4.5	4.9	4.5	4.5	4.7	5 NTU	4.7
P.H.	7.0	7.0	7.0	7.1	7.1	7.1	7.0	7.1	7.4	7.4	7.3	7.3	7.2	7.3	7.1	7.1	7.0	7.1	7.0	6.5-8.5	7.1
ALCALINIDAD TOTAL	112	120	120	110	144	154	140	150	166	152	150	160	164	152	144	148	144	154	156		144
DUREZA TOTAL	396	422	420	436	476	480	458	456	450	464	470	452	448	459	486	458	464	462	440	500 MG/LT	451
DUREZA DE CALCIO	258	266	272	280	316	298	320	300	302	312	316	310	320	282	286	298	306	304	290		297
D. DE MAGNESIO	138	154	148	156	160	162	138	156	148	152	154	142	128	186	178	160	158	158	150		154
CLORUROS	230	228	236	240	240	235	228	216	220	222	226	235	240	246	238	240	248	250	250	250 MG/LT	235
CLORO RESIDUAL	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.3	1.4	1.5	1.4	1.5	1.5	1.4	1.4	1.5	1.2	1.4	1.1	0.2-1.5	1.4
SDT	795	763	747	886	916	956	978	980	963	990	995	984	988	994	992	973	945	940	957	1000 MG/LT	934
TEMPERATURA °C	17.9	19.6	16.1	13.7	13.3	14.5	16.0	16.3	15.1	16.6	17.3	19.0	17.3	19.4	20.6	22.2	13.5	15.7	14.4		17

AUTORIZO:

I.Q. EDNA MARISSA SOTO LOZANO  
ENCARGADA DE LABORATORIO

BIOLDO GUILLERMO NAVAJUANO  
COORDINADOR DE CALIDAD DEL AGUA

Vo.Bo.