



GOBIERNO MUNICIPAL DE
REYNOSA
ADMINISTRACIÓN 2021 - 2024

COMAPA
REYNOSA

PLANTA POTABILIZADORA PASTOR LOZANO

COM
GOBIERNO DEL ESTADO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA RÍO BRAVO
FEBRERO 2022

RESULTADOS EN MG/L T

FECHA:	1	2	3	4	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	PROMEDIO
TURBIDEAD N.T.U.	15.9	13.2	14.7	17.5	10.3	8.8	6.6	9.4	10.5	11.9	12.0	15.9	19.3	10.4	13.8	14.8	16.5	15.0	16.8	13
P.H.	7.7	7.5	7.6	7.5	7.8	7.5	7.7	7.7	7.7	7.8	7.8	7.6	7.7	7.8	7.5	7.9	7.7	7.8	7.5	7.7
ALCALINIDAD TOTAL	104	112	106	120	160	160	162	164	176	170	170	172	176	168	160	158	164	164	166	154
DUREZA TOTAL	410	410	412	420	540	500	476	480	500	500	500	486	490	462	474	472	484	488	444	470
DUREZA DE CALCIO	248	226	232	272	380	368	346	330	368	356	364	350	340	314	290	324	330	326	282	319
D. DE MAGNESIO	162	184	180	148	160	132	130	130	132	144	136	136	150	148	184	148	154	160	162	151
CLORUROS	235	235	226	318	334	323	310	305	327	345	342	358	350	317	308	310	321	340	277	310
SDT	773	755	750	1041	1204	1082	1040	1024	1146	1132	1123	1161	1317	1109	1059	1063	1089	1152	1054	1056
TEMPERATURA OC	17.2	19.3	16.5	13.5	12.7	13.3	15.0	15.6	13.3	14.8	17.1	18.6	15.0	19.7	20.3	21.7	15.0	13.5	14.6	16

AUTORIZO:

Edna Marissa Soto Lozano
I.Q. EDNA MARISSA SOTO LOZANO
ENCARGADA DE LABORATORIO

[Signature]
BIOLÓGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA