

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS  
AGUA POTABLE  
MARZO 2022

RESULTADOS EN MG/LT																															
FECHA:	1	2	3	4	7	8	9	10	11	14	16	16	17	18	21	22	23	24	25	28	29	30	31	NOM- 127/94	PROMEDIO						
TURBIEDAD N.T.U.	5.0	4.6	4.5	5.0	4.5	4.8	4.6	5.0	4.9	5.0	4.8	4.7	4.8	4.9	4.6	4.8	4.6	4.9	4.7	4.8	5.0	4.8	4.7	5 NTU	4.8						
P.H.	7.2	7.0	7.1	7.0	7.2	7.6	7.7	7.1	7.5	7.4	7.5	7.3	7.3	7.3	7.1	7.2	7.3	7.5	7.1	7.1	7.0	7.0	7.0	6.5-8.5	7.2						
ALCALINIDAD TOTAL	148	142	148	148	144	140	152	154	160	150	140	140	140	160	180	140	138	148	136	130	116	114	118		142						
DUREZA TOTAL	500	498	446	412	366	374	348	390	384	340	340	350	330	324	340	360	336	330	350	310	352	368	364	500 MG/LT	370						
DUREZA DE CALCIO	360	362	322	222	218	224	220	240	246	218	210	218	212	208	216	220	200	190	194	182	172	202	212		229						
D. DE MAGNESIO	140	124	126	190	148	150	128	150	138	122	130	132	118	116	124	140	136	140	156	128	180	164	152		141						
CLORUROS	242	246	244	236	244	233	240	245	241	236	215	210	205	210	240	250	225	225	217	190	205	200	220	250 MG/LT	227						
CLORO RESIDUAL	1.5	0.9	1.5	1.5	1.4	1.4	1.5	1.5	1.5	1.5	1.4	1.5	1.4	1.3	0.9	1.5	1.5	1.0	1.5	1.5	1.3	1.5	1.5	0.2-1.5	1.4						
SDT	965	941	927	906	905	881	984	986	991	990	986	962	955	966	985	989	975	970	986	892	743	698	716	1000 MG/LT	938						
TEMPERATURA OC	14.7	16.2	18.3	19.6	21.7	17.9	17.1	17.0	18.9	17.8	19.8	19.9	21.0	22.9	22.4	23.1	22.3	21.4	21.3	22.4	22.4	24.2	24.6		20						

AUTORIZO:

*Edna Horta Lopez*  
I.O. EDNA MARISSA SOTO LOZANO  
ENCARGADA DE LABORATORIO

*[Signature]*  
BIROSO ENILEMO NAVA-ELIJANO  
COORDINADOR DE ENTIDAD DEL AGUA