


PLANTA POTABILIZADORA PASTOR LOZANO
ANALISIS FISICOQUIMICOS
AGUA POTABLE
jul-18

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	4.8	5.0	4.8	5.0	5.0	4.5	4.2	4.4	4.9	5.0	5.0	3.8	4.6	4.8	5.0	5.0	4.8	4.9	5.0	5.0	4.7	5.0	5 NTU.	4.8
P.H.	6.9	6.9	7.0	7.0	7.0	7.1	7.0	7.1	7.5	7.2	7.3	7.2	7.8	7.1	7.2	7.3	7.3	7.1	7.2	7.1	7.0	7.1	6.5-8.5	7.2
ALCALINIDAD TOTAL	108	108	96	100	116	110	110	106	100	100	90	94	98	114	102	94	84	92	98	96	90	104		100.5
DUREZA TOTAL	250	248	250	240	250	245	250	248	250	246	250	250	250	246	250	248	240	250	246	250	250	248	500 MG/LT	248.0
CLORUROS	205	244	214	210	190	240	335	320	280	250	278	280	250	240	236	231	200	209	203	200	168	199	250 MG/LT	233.7
CLORO RESIDUAL	1.5	1.5	1	1.1	1.4	1	1.5	1.5	1.5	1.5	1	1.5	1.2	1.2	1.5	0.5	1.3	1.5	1.5	1.5	1.5	1.3		1.3
CALCIO	166	174	160	142	126	156	150	126	148	120	172	140	128	130	128	156	128	148	154	124	190	170		147.1
MAGNESIO	174	168	192	208	126	166	140	192	180	200	142	160	176	164	162	140	148	144	146	150	100	130		159.5
SDT	734	768	749	921	632	705	588	520	469	445	363	351	354	370	308	720	568	591	574	578	494	551	1000 MG/LT	561.5

Realizó



OFB MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO

RECIBIDO



RICARDO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

Recibido
08/Jul/2018



RECIBI EL 08 Aso - 2018

RECIBI EL 10/07/2018
ING. ROY. PONCE
VENOZ
C.N.A