


PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
abr-17

RESULTADOS EN MG/LT


FECHA:	3	4	5	6	7	10	11	12	17	18	19	20	21	24	25	26	27	28	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	20.9	24.0	22.4	21.4	23.1	29.7	28.9	44.1	28.1	22.4	20.9	17.3	16.9	47.7	38.0	31.1	40.7	37.4	5 NTU.	28.6
P.H.	7.9	8	7.8	7.8	8	7.9	7.9	7.7	7.7	8	8.2	7.9	8.2	7.8	7.8	7.8	7.8	7.7	6.5-8.5	7.9
ALCALINIDAD TOTAL	92	86	96	92	92	92	92	92	92	90	116	96	124	96	100	80	100	102		96.2
DUREZA TOTAL	256	260	276	300	306	320	280	292	214	310	250	368	260	288	260	290	288	290	500 MG/LT	283.8
CLORUROS	165	176	158	150	160	149	156	180	127	150	150	163	161	167	155	170	165	160	250 MG/LT	159.0
CLORO RESIDUAL																				
CALCIO	166	188	190	180	170	150	170	180	122	134	122	120	130	170	176	180	168	178		160.8
MAGNESIO	90	72	86	120	136	170	110	112	92	176	128	248	130	118	84	110	120	112		123.0
SDT	469.5	493	506.5	497	502	497	496.5	502.2	514	505	502	501	506	510	497	513	498	1000 MG/LT		500.9

Realizó



QFB MIRYAM CAVAZOS GARCÍA
JEFE DE LABORATORIO

Vo. Bo.



BIOL. JUAN GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA