

PLANTA POTABILIZADORA PASTOR LOZANO  
ANALISIS FISICOQUIMICOS  
AGUA POTABLE  
ago-18

RESULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	31	NOM- 127/94	PROMEDIO
TURBIEDAD N.T.U.	2.6	2.0	2.5	1.6	1.4	2.0	2.0	2.4	1.9	2.4	1.9	1.9	1.8	2.8	2.2	2.5	2.2	2.1	3.8	2.5	2.2	3.2	2.0	5.0	2.3
P.H.	7.1	7.6	7.3	7.2	7.2	7.2	7.2	7.2	7.2	7.1	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.1	7.1	7.2	7.4	7.4	6.5-8.5	7.2
ALCALINIDAD TOTAL	90	98	104	106	884	96	100	94	88	98	96	100	96	90	96	88	96	98	80	94	96	96	98		129.2
DUREZA TOTAL	312	292	300	280	286	280	304	292	275	302	310	296	288	274	276	280	298	276	280	298	304	288	300	500 MG/LT	290.9
CLORUROS	201	195	200	183	198	196	203	192	175	204	207	213	211	201	200	215	219	215	194	210	207	216	206	250 MG/LT	202.7
CLORO RESIDUAL	1.2	1.5	1.4	1.5	1.5	1.3	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.5
CALCIO	164	168	178	158	174	168	174	146	172	162	174	184	166	170	172	170	174	160	178	164	166	176	172		169.1
MAGNESIO	148	124	122	122	112	112	130	146	103	140	136	112	122	104	104	110	124	116	102	134	138	112	128		121.8
SDT	545	657	646	639	545	556	499	494	494	609	625	601	590	607	693	698	861	885	626	626	615	608	636	1000 MG/LT	624.1

Realizo

*Miriam Cavazos Garcia*  
OFB. MIRIAM CAVAZOS GARCIA  
JEFE DE LABORATORIO

*Dom & Dora*

Vo. Bo.

*Roberto Guillermino Nava Lujano*  
COORDINADOR DE CALIDAD DEL AGUA

