

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA POTABLE  
ABRIL 2022


RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/84	PROMEDIO
TURBIEDAD N.T.U.	4.3	4.8	4.9	4.2	5.0	4.8	5.0	4.2	4.8	4.2	5.0	4.8	4.4	4.5	4.6	4.3	4.9	4.6	4.3	5.0	4.1	5 NTU	4.6
P.H.	6.9	7.0	6.9	7.3	7.0	7.0	7.0	7.2	7.0	7.0	7.0	6.9	7.1	7.0	7.2	7.1	7.0	6.9	6.8	6.9	7.0	6,5-8,5	7.0
ALCALINIDAD TOTAL	124	112	114	122	104	108	110	112	114	116	108	128	128	128	122	126	120	122	112	112	112		117
DUREZA TOTAL	346	336	350	340	336	300	308	318	326	330	328	340	370	380	358	340	336	332	340	346	330	500 MG/LT	338
DUREZA DE CALCIO	202	196	208	196	202	190	194	192	200	196	198	196	174	186	170	142	140	212	218	220	166		190
D. DE MAGNESIO	144	140	142	144	134	110	114	126	126	134	130	144	196	194	188	198	196	120	122	126	164		147
CLORUROS	211	185	196	168	176	167	185	189	185	182	177	180	193	201	190	183	178	192	200	192	192	250 MG/LT	187
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.4	1.5	1.5	1.5	1.4	1.0	1.3	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	685	634	630	548	580	539	573	548	560	589	621	633	651	668	651	635	651	558	734	668	680	1000 MG/LT	621
TEMPERATURA °C	24.4	26.0	25.9	26.6	25.9	24.4	25.5	26.8	26.8	27.5	26.6	27.4	27.1	26.7	26.4	26.6	27.0	26.6	25.0	26.0	26.3		26

AUTORIZÓ:

  
I.Q. EDNA MARISSA SOTO LOZANO  
ENCARGADA DE LABORATORIO

Vg. Bg.

  
BIÓLOGO GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA