

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA CANAL RODHE
ABRIL 2022


RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	23.8	36.8	79.1	61.1	54.5	41.9	38.1	39.5	37.7	38.3	30.8	38.6	45.5	35.2	33.7	32.6	23.6	29.6	22.1	20.6	35.5	38
P.H.	7.1	7.4	7.5	7.5	7.8	7.6	7.5	7.8	7.2	7.4	7.8	7.2	7.3	7.2	7.5	7.4	7.2	7.4	7.6	7.6	7.8	7.5
ALCALINIDAD TOTAL	126	114	120	118	114	112	116	116	112	124	132	134	128	152	120	130	124	128	118	110	124	122
DUREZA TOTAL	368	376	380	376	364	366	362	366	384	394	390	410	440	440	422	440	430	394	426	396	400	397
DUREZA DE CALCIO	240	270	240	240	214	230	228	230	234	228	210	168	190	220	172	154	142	244	232	232	180	214
D. DE MAGNESIO	128	106	140	136	150	136	134	156	150	166	180	242	250	220	250	286	288	150	194	166	220	183
CLORUROS	245	237	241	226	230	226	220	230	242	250	240	233	246	240	250	235	240	224	244	236	236	237
SDT	796	773	753	734	727	712	712	704	695	739	789	790	794	795	799	789	641	635	824	792	795	752
TEMPERATURA °C	23.4	25.5	24.9	25.7	23.8	22.6	24.3	25.5	26.3	26.5	26.5	27.0	26.5	25.7	25.5	26.0	26.4	26.0	25.1	25.5	25.7	25

AUTORIZÓ:

Va.Bo.


I.Q. EDNA MARISSA SOTO LOZANO
ENCARGADA DE LABORATORIO


BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA