

PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
MAYO 2022

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	NOM-127/84	PROMEDIO
TURBIEDAD N.T.U.	4.6	4.7	4.3	4.7	4.8	4.9	4.4	4.7	4.4	4.7	5.0	4.9	4.5	4.5	4.1	4.7	5.0	5.0	4.6	4.9	4.8	5.0	5 NTU	4.7
P.H.	7.1	7.0	7.1	7.0	7.0	6.8	7.2	7.1	7.0	7.0	6.9	6.9	6.8	6.6	7.1	6.8	6.8	6.9	7.0	7.0	7.1	6.9	6.5-8.5	7.0
ALCALINIDAD TOTAL	112	116	114	108	122	126	134	136	122	126	118	114	110	116	114	126	120	126	112	110	114	112		119
DUREZA TOTAL	370	364	336	342	348	344	360	350	364	332	322	378	352	354	354	324	336	364	360	352	374	352	500 MG/LT	351
DUREZA DE CALCIO	186	180	190	186	160	184	180	154	160	164	168	218	190	166	172	186	190	166	222	196	204	174		181
D. DE MAGNESIO	184	184	146	156	188	160	180	196	204	178	154	180	162	188	182	138	146	198	138	156	170	178		170
CLORUROS	224	250	250	248	240	250	238	231	210	219	219	200	189	200	184	190	192	205	225	218	242	250	250 MG/LT	222
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.4	1.5	1.4	1.1	1.5	1.4	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	0.2-1.5	1.5
SDT	719	859	855	792	764	769	740	869	678	639	708	752	703	888	990	744	689	689	699	684	739	746	1000 MG/LT	753
TEMPERATURA oC	27.3	27.7	27.4	27.6	28.3	29.4	28.9	29.4	28.5	28.6	29.5	28.3	28.5	28.3	28.6	28.9	27.4	27.1	27.9	29.2	29.4	30.5		28

AUTORIZÓ:


I.Q. EDNA MARISSA SOTO LOZANO
ENCARGADA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA